

Town of Amherst  
Police Station Design & Build  
Addendum #3

1. Do you want the offices to be keyed locks? **Yes**

3. Do you want the secretary window fixed or a sliding window? **Fixed**

3. The exterior door on the side of the building will be hollow metal door going into the existing aluminum storefront frame, this is a flush door (no glass kit). Correct? **Yes**

Can we reusing the existing closer? **Yes**

Does this need to have a keyed exterior? **Yes**

4. How does county want to handle the abatement survey and or cost of the abatement – I suggest not including in the bid. **Do not include in the bid.**

5. Gun room do you want a hard sheetrock ceiling in that room? **Yes**

6. Gun room door should be a steel door and steel jamb with a deadbolt and keyed lock correct? **Yes**

7. Upon my second visit we discovered some thing down stairs no up to par – Still no work down stairs correct?

**No work downstairs**

8. Can we use the wood platform at the basement door to hold the HVAC out door unit? The current platform can be used if it can be moved. **We would prefer the platform to be moved if possible. We would like for there to be nothing blocking the basement door and garage door. We would like the HVAC to be put in the rear of the building . The platform can be used if it can be used somewhere else.**

9. Do you want the GC to state c/o percentage cost and the percentage that the sub-contractor can charge on the c/o as well? **Yes**